

Industrial Wastewater Pretreatment Monitoring Report

Sampling Point #2 (Part 1, A&B)

Milbank Mfg

Year 00 Month FEB.

Date	Flow	pH	Cd	Cr	Cu	Ni	Ag	Pb	Zn	Mo	TTO	Phenol	CN	TPH	FOG	NH3	CBOD	COD	TSS
1	1770	9.93																	
2	3340	9.91							4.020	.032						6.1	51	200	18
3																			
4																			
5																			
6																			
7																			
8																			
9																			
10	3580	9.76							.069										
11	1000	9.89																	
12																			
13																			
14	870	9.62																	
15	1530	9.82																	
16	1410	9.92																	
17	3000	9.90							.038										
18	3090	9.89																	
19																			
20																			
21																			
22	5	9.03																	
23	3000	9.92																	
24	3470	9.85							.030										
25	2480	9.85																	
26																			
27																			
28	970	9.58																	
29	1890	9.75																	
30																			
31																			
Daily LIMIT	N/A	N/A	.02	2.0	.6	.8	.24	.1	1.25	N/A	2.13	.5	.5	N/A	100	N/A	N/A	N/A	N/A
Average	2242	9.77							.039							6.1	51	200	18
Maximum	3580	9.93							.069							6.1	51	200	18
Minimum	870	9.03							4.020							6.1	51	200	18

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Richard Zylar
Authorized Company Representative

DATE 3-17-00